

Table 3.11. Average Costs of Existing Flue Gas Desulfurization Units, 1999 through 2010

Year	Average Operation & Maintenance Costs (mills per kilowatthour)[1]	Average Installed Capital Costs (dollar per kilowatt)
1999	1.13	125
2000	0.96	124
2001	1.27	130.8
2002	1.11	124.18
2003	1.23	123.75
2004	1.38	144.64
2005	1.23	141.34
2006	NA	NA
2007	1.51	135.29
2008	1.55	150.74
2009	1.61	186.73
2010	1.62	289.64

[1] A mill is one tenth of one cent.

NA = Not available. Form EIA-767 data collection was suspended in the data year 2006.

Notes: • Data for 2007 through 2009 reflect a minor revision to the aggregation methodology as compared to previous years. The new methodology takes generator status into account where previously the data only reflected boiler and flue gas desulfurization unit statuses. • Data for Independent Power Producer and Combined Heat and Power plants are included beginning with 2001 data. • Totals may not equal sum of components because of independent rounding.

Sources: Through 2005, U.S. Energy Information Administration, Form EIA-767, "Steam-Electric Plant Operation and Design Report;" and from 2007 forward, U.S. Energy Information Administration, Form EIA-860, "Annual Electric Generator Report" for Average Installed Capital Costs, and Form EIA-923, "Power Plant Operations Report" for Average Operation & Maintenance Costs.